INTERTEK WARNOCK HERSEY
FIRE DOOR LABEL REQUIREMENTS

This sheet is intended to address the required information that must be included on the Aluminum or Mylar fire door labels containing the Intertek WH Certification Mark. These guidelines are based on NFPA 80, Standard for Fire Doors and Other Opening Protectives, IBC, and Intertek requirements. The label shall only be applied at the factory receiving Follow-up Service.

THE LABEL



REQUIRED INFORMATION

1. The words "XX Minute Fire Door"
2. Intertek Warnock Hersey Certification Mark with applicable country identifiers
3. Intertek W/N Number under Certification Mark. This number is assigned by the Intertek Labeling Department
4. The manufacturer or machiner company name, or a code that can be traced back to the company
   - For companies with multiple locations, the location or location code can be noted on the label
5. The Test Standard(s) to which the door was tested to
   - Certified to: UL 10 (B and/or C), NFPA 252, CAN/ULC S104
   - Exception: If 20 Minute Fire Door without Hose Stream, CAN/ULC S104 shall not be included on label and "Without Hose Stream" shall be included with the rating
6. Serial Number
7. "DO NOT COVER OR REMOVE THIS LABEL"
8. The words "SEE INSTALLATION INSTRUCTIONS"
9. Minimum Latch Bolt Throw
   - For swinging doors provided with builders hardware

OPTIONAL/SUPPLEMENTAL INFORMATION

10. "S" with statement, "Smoke & Draft Control requires installation of Listed Category H Gasket"
    - May be on a supplemental Label
11. "Fire Door To Be Equipped With Fire Exit Hardware" (Not Shown)
    - May be on supplemental label
12. Temperature transmission rate at 30 minutes for Fire Doors exceeding 20 Minute Fire Rating (Not Shown)
    - If temperature exceeds 650°F (361°C), temperature rise can be omitted

FOR MORE INFORMATION

855.944.2378 bpcerthelpdesk@intertek.com intertek.com/building/markets/fire-door/